

Отчет о суточных параметрах
(01.12.2023 0:00:00 - 31.12.2023 0:00:00)

Объект: Пермь г, Адмирала Ушакова ул, д. 22 (ООО "КРИСТАЛЛ")

Прибор: ЭЛТЕКО ТС555 Заводской номер: 9741

Точка измерения: УУ1; Ресурс: ТС

Датчик температуры:

Подача: ВЗЛЕТ ТПС SN 1152195

Обратка: ВЗЛЕТ ТПС SN 1152127

Схема измерений: Пользовательская

| Дата | t1 | t2 | V1 | V2 | M1 | M2 | Qтс | ВНР |
|------------|--------|--------|---------|---------|---------|---------|--------|-------|
| | град.С | град.С | м.куб | м.куб | т | т | Гкал | ч |
| 01.12.2023 | 55.58 | 43.31 | 78.10 | 78.20 | 77.00 | 77.60 | 0.950 | 24.0 |
| 02.12.2023 | 56.99 | 44.41 | 79.30 | 80.40 | 78.10 | 79.60 | 0.987 | 24.0 |
| 03.12.2023 | 59.38 | 45.67 | 78.20 | 78.60 | 76.90 | 77.80 | 1.060 | 24.0 |
| 04.12.2023 | 59.60 | 46.08 | 79.10 | 80.50 | 77.90 | 79.70 | 1.058 | 24.0 |
| 05.12.2023 | 63.86 | 48.43 | 78.40 | 79.50 | 76.90 | 78.60 | 1.191 | 24.0 |
| 06.12.2023 | 70.78 | 52.57 | 79.30 | 80.70 | 77.50 | 79.70 | 1.415 | 24.0 |
| 07.12.2023 | 75.87 | 54.97 | 78.20 | 80.00 | 76.30 | 78.90 | 1.599 | 24.0 |
| 08.12.2023 | 74.79 | 54.20 | 79.30 | 81.10 | 77.40 | 79.90 | 1.598 | 24.0 |
| 09.12.2023 | 76.09 | 54.43 | 78.60 | 80.20 | 76.50 | 79.20 | 1.664 | 24.0 |
| 10.12.2023 | 72.31 | 52.44 | 79.50 | 81.20 | 77.70 | 80.10 | 1.547 | 24.0 |
| 11.12.2023 | 75.13 | 53.74 | 78.80 | 80.40 | 76.80 | 79.30 | 1.648 | 24.0 |
| 12.12.2023 | 73.63 | 53.03 | 79.80 | 81.50 | 77.90 | 80.40 | 1.609 | 24.0 |
| 13.12.2023 | 76.46 | 54.68 | 79.40 | 81.10 | 77.40 | 80.00 | 1.691 | 24.0 |
| 14.12.2023 | 71.63 | 52.36 | 79.90 | 81.50 | 78.10 | 80.40 | 1.510 | 24.0 |
| 15.12.2023 | 68.60 | 50.61 | 78.70 | 80.20 | 77.00 | 79.20 | 1.390 | 24.0 |
| 16.12.2023 | 62.75 | 47.31 | 79.60 | 80.90 | 78.10 | 80.10 | 1.210 | 24.0 |
| 17.12.2023 | 64.63 | 48.38 | 78.70 | 80.10 | 77.30 | 79.20 | 1.259 | 24.0 |
| 18.12.2023 | 59.70 | 45.69 | 79.50 | 80.80 | 78.20 | 80.00 | 1.101 | 24.0 |
| 19.12.2023 | 56.00 | 43.42 | 78.70 | 79.90 | 77.50 | 79.10 | 0.979 | 24.0 |
| 20.12.2023 | 49.57 | 39.51 | 79.40 | 80.40 | 78.50 | 79.80 | 0.796 | 24.0 |
| 21.12.2023 | 48.88 | 38.92 | 78.20 | 78.20 | 77.40 | 77.70 | 0.775 | 24.0 |
| 22.12.2023 | 48.74 | 39.04 | 79.00 | 80.00 | 78.10 | 79.40 | 0.763 | 24.0 |
| 23.12.2023 | 50.04 | 39.83 | 78.10 | 78.10 | 77.20 | 77.60 | 0.794 | 24.0 |
| 24.12.2023 | 51.03 | 40.54 | 79.30 | 80.30 | 78.30 | 79.70 | 0.827 | 24.0 |
| 25.12.2023 | 51.57 | 40.87 | 78.20 | 78.40 | 77.30 | 77.70 | 0.832 | 24.0 |
| 26.12.2023 | 52.63 | 41.68 | 79.10 | 80.20 | 78.10 | 79.50 | 0.861 | 24.0 |
| 27.12.2023 | 54.83 | 42.75 | 77.90 | 77.80 | 76.70 | 77.20 | 0.932 | 24.0 |
| 28.12.2023 | 59.35 | 45.73 | 79.00 | 80.30 | 77.80 | 79.50 | 1.064 | 24.0 |
| 29.12.2023 | 61.19 | 46.58 | 78.00 | 78.70 | 76.70 | 77.90 | 1.124 | 24.0 |
| 30.12.2023 | 63.75 | 48.13 | 79.40 | 80.90 | 77.90 | 80.00 | 1.221 | 24.0 |
| 31.12.2023 | 69.45 | 51.33 | 78.30 | 80.00 | 76.60 | 79.00 | 1.395 | 24.0 |
| Средние: | 62.41 | 47.12 | --- | --- | --- | --- | --- | --- |
| Итого: | --- | --- | 2445.00 | 2480.10 | 2401.10 | 2453.80 | 36.850 | 744.0 |

| Дата | V1 | V2 | M1 | M2 | Qтс | ВНР итог |
|------------|-----------|-----------|-----------|-----------|----------|----------|
| | м.куб | м.куб | т | т | Гкал | ч |
| 30.11.2023 | 158894.50 | 156116.40 | 156679.20 | 154594.90 | 1489.716 | 60462.4 |
| 31.12.2023 | 161339.50 | 158596.50 | 159080.30 | 157048.70 | 1526.566 | 61206.4 |
| Итого: | 2445.00 | 2480.10 | 2401.10 | 2453.80 | 36.850 | 744.0 |

Представитель абонента

Представитель энергоснабжающей организации